

IAS EnviroChem
3314 Pole Line Rd. • Pocatello, ID 83201
Phone: (208) 237-3300 • Fax: (208) 237-3336
email: iasec3308@iasenvirochem.com • www.iasenvirochem.com

EPA Laboratory Number: ID00952

Microbiological Analysis Report

City of Soda Springs-Alan Skinner
Alan Skinner
9 W. 2nd South
Soda Springs, ID 83276

Lab Sample ID:	M609179-01	Jurisdiction:	Pocatello DEQ
Collection Date:	9/14/16 13:30	Date Received by Lab:	9/14/16 15:35
Water System:	6150017 - Total Coliform P/A		
Sample ID/Location:	Hospital		
Collector Name:	Kelly Hill	Collector Phone:	(208) 547-2600

Method Desc: SM9223B P/A Colilert

Cmp Name	Result	Analysis Date/Time	Analyst
Total Coliforms	Absent /100 ml	9/14/16 17:00	MAD
E. coli	Absent /100 ml	9/14/16 17:00	MAD

Aux. Data

Sample Type Code: S - Routine Sample
Residual Chlorine (ppm): 0.27
PWS Date of Original Positive:
PWS Repeat Sample Location:
Tag #/ Facility ID:



9/15/2016

Signature of Laboratory Supervisor

Date