

EPA Laboratory Number: ID00952

Microbiological Analysis Report

City of Soda Springs-Alan Skinner
Alan Skinner
9 W. 2nd South
Soda Springs, ID 83276

Lab Sample ID:	M611040-01	Jurisdiction:	Pocatello DEQ
Collection Date:	11/2/16 12:50	Date Received by Lab:	11/2/16 15:45
Water System:	6150017 - Total Coliform P/A		
Sample ID/Location:	Hospital		
Collector Name:	Zac Caudill	Collector Phone:	(208) 547-2600

Method Desc: SM9223B P/A Colilert

Cmp Name	Result	Analysis Date/Time	Analyst
Total Coliforms	Absent /100 ml	11/2/16 16:45	MAD
E. coli	Absent /100 ml	11/2/16 16:45	MAD

Aux. Data

Sample Type Code: S - Routine Sample
Residual Chlorine (ppm): 0.41
PWS Date of Original Positive:
PWS Repeat Sample Location:
Tag #/ Facility ID:



11/3/2016

Signature of Laboratory Supervisor

Date